

AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 38617

Date: 10/19/2021

Detailed Product Description:


Manufacturer: ROOF TECH, INC.

Manufacturer Address: 10620 TREENA ST. SUITE 230, SAN DIEGO, CA 92131

Model Name: RT-APEX ROOF TOP PV MOUNTING SYSTEM

Maximum Load: +80.2 PSF, -80.2 PSF (Non-Impact)

Installation Drawings # 21-70F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum wind uplift and shear resistance vs fastening option refer to installation drawings.					
Tested in accordance with TAS-100(A) & ASTM D1761					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT	TEST REPORT #	TEST SEALED BY
TAS 100(A)	Wind Driven Rain Resistance	Intertek	07/02/2020 07/02/2020	K8679.01-109-18 K8680.01-109-18	Daniel C. Culbert, PE
ASTM D1761	Mechanical Fasteners in Wood and Wood-Based Materials	Institute of Building Technology	05/19/2021	2426-21008	Bart W Berneche, PE
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.					
Evaluation Report Engineer:					
Jalal Farooq Al-Farooq Corporation		PE # 81223 EB # 3538			
			Sealed: 10/19/2021		