





8431 Murphy Drive  
 Middleton, WI 53562 USA  
 Telephone: 608.836.4400  
 Facsimile: 608.831.9279  
 www.intertek.com

# Test Verification of Conformity

In the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

<b>Applicant Name &amp; Address:</b>	Roof Tech Inc. 333 H Street, Suite 5000 Chula Vista, CA 91910		
<b>Product Description:</b>	Photovoltaic Mount		
<b>Ratings &amp; Principle Characteristics:</b>	<u>Fire Class Resistance Rating:</u> -Flush Mount (Symmetrical). Class A Fire Rated for Steep Slope applications when using Type 2 listed photovoltaic modules. Both products evaluated with a 5" gap (distance between the bottom the module's frame and the roof covering), per Section 31.2.2.1 of UL 1703 this product can be installed with any gap stated in the manufacturers installation instructions. No perimeter guarding is required.		
<b>Models:</b>	RT-E and RT-E Air Mount		
<b>Brand Name:</b>	Roof Tech		
<b>Relevant Standards:</b>	UL 2703 (Section 15.2 and 15.3) Standard for Safety Mounting Systems, Mounting Devices, Clamping/Retention Devices with Flat-Plate Photovoltaic Modules and Panels, First Edition dated Jan. 28, 2015 <b>Referencing</b> UL1703 Third Edition revision date Oct, 2015, (Section 31.2) Standard for Safety for Flat-Plate Photovoltaic Modules and Panels.		
<b>Verification Issuing Office:</b>	Intertek Testing Services NA, Inc. 8431 Murphy Drive Middleton, WI 53562		
<b>Date of Tests:</b>	06/10/2016 to 06/16/2016		
<b>Test Report Number(s):</b>	102611432MID-002r1.		
<b>This verification is part of the full test report(s) and should be read in conjunction with them. This report does not automatically imply product certification.</b>			
<b>Completed by:</b>	Christopher Zimbrich	<b>Reviewed by:</b>	Chad Naggs
<b>Title:</b>	Technician II, Fire Resistance	<b>Title:</b>	Technician I, Fire Resistance
<b>Signature:</b>		<b>Signature:</b>	
<b>Date:</b>	06/20/2016	<b>Date:</b>	06/20/2016

*This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*